


2024 CONSUMER CONFIDENCE REPORT

KING COUNTY WATER DISTRICT NO. 119

JUNE 2025



District's Mission Statement

The mission of the District is to provide safe, high quality potable water service in an efficient and cost effective manner with a high level of customer satisfaction.

Inside This Report

- *Where does our water come from?*
- *How is the water source protected?*
- *What is in our drinking water?*
- *Water quality and you*
- *Water conservation*
- *How can I get more information*



ANNUAL WATER QUALITY REPORT

King County Water District No. 119 (WD119) is pleased to bring you our annual water quality report. As our customer, you have a right to fully understand the operations of your water district. WD119 is committed to ensuring the quality of its system and its compliance with government standards. This report is intended to provide you with information on the quality of your drinking water. For those of you who are new to WD119, the information contained in this report should be enlightening. For those of you who have received the report in the past, the information will appear similar with a few exceptions. This report, and some of the actual text, are required by the Federal Safe Drinking Water Act (SDWA), and we will continue to send you an update each year. Although parts of this report may seem repetitive, it is the intent of WD119 to make it as informative and useful as possible. The District welcomes comments and suggestions regarding this report and the services we provide. We will do our best to incorporate the recommendations we receive into our next publication. We hope you'll find the information contained in this report useful. Drinking water is our most precious resource, and we are committed to delivering safe water of the highest quality to your home and place of work. We encourage all customers to use water wisely, and we appreciate your conservation efforts.

ABOUT YOUR WATER SUPPLY

All of WD119's water is supplied by the Seattle's Public Utility Department's (SPU) Tolt River Watershed. The watershed consists of 12,500 acres of uninhabited land and a surface water reservoir that can store up to 18.3 billion gallons of water. The reservoir is supplied with water from rivers, streams, snowmelt and 90 to 160 inches of precipitation per year. From the reservoir, the water enters into the Tolt River Treatment Facility. After the water is treated, it then travels 7.5 miles west through a supply pipeline to WD119 and other eastside cities and water districts on its way to Seattle. The District is the first customer on the pipeline with two taps.

WATER SOURCE ASSESSMENT

Providing protection for the water source is very important to the quality of our water. SPU protects your drinking water by enforcing an aggressive watershed protection plan. No agricultural, industrial or recreational activities are allowed in the area. Access to the watershed is restricted to only authorized staff, and participants in scheduled educational programs conducted by SPU staff. The Washington State Department of Health (DOH) has determined the Tolt River Watershed to have a low vulnerability to contamination. This means there is little opportunity for contaminants to enter the water.

IMPORTANT INFORMATION ABOUT THIS REPORT

This Consumer Confidence Report (CCR) summarizes the testing of contaminants in our drinking water. Every year, the District and other water providers are required to prepare and distribute a CCR to all water customers. This CCR includes a comparison of the District's water to water quality standards set by the DOH and the U.S. Environmental Protection Agency (EPA). The purpose of the report is to let you, our customers, know the quality of your water.

QUESTIONS . . . ?

If you want to learn more about the District, visit our website at wd119.org or attend our board meetings held on the first Wednesday of the month. Visit the website to confirm the time and location of the meeting. If you have questions about this report please contact the District Office by phone at (425) 788-2885 or by email at office@wd119.org.

BOARD OF COMMISSIONERS

Yuri Kreutzer
Terry Olson
Mike Smith

WATER QUALITY DATA

The monitoring results for 2024 are summarized in the table. The results are for those parameters found in our water which are regulated by federal and state agencies. The first two columns list each compound found and the units of measure. The third and fourth columns list the EPA's goals and allowable limits. The fifth and sixth columns list the levels found in our supply. The seventh column indicates if the water meets the required standards. The last column is where these compounds may come from or how they are formed.

Detected Compound	Units	EPA's Allowable Limits		Your Water		Compliant (Y/N)	Typical Sources
		MCLG	MCL	Average	Range		

Raw Water (untreated water from the source)

Total Organic Carbon	ppm	NA	TT	1.24	1.12 to 1.39	Y	Naturally present in the environment
----------------------	-----	----	----	------	--------------	---	--------------------------------------

Finished Water (treated water that is ready to drink)

Turbidity	NTU	NA	TT	0.04	0.02 to 0.29	Y	Soil Runoff
-----------	-----	----	----	------	--------------	---	-------------

Fluoride	ppm	4	4	0.7	0.6 to 0.8	Y	Water additive to which promotes strong teeth
----------	-----	---	---	-----	------------	---	---

Barium	ppm	2000	2000	1.2	1.1 to 1.4	Y	Erosion of natural deposits
--------	-----	------	------	-----	------------	---	-----------------------------

Bromate	ppm	0	10	0.3	ND to 3.8	Y	Byproduct of drinking water disinfection
---------	-----	---	----	-----	-----------	---	--

Arsenic	ppb	0	10	0.23	0.2 to 0.3	Y	Erosion of natural deposits
---------	-----	---	----	------	------------	---	-----------------------------

Nitrate	ppm	0	5	0.08	1 Sample	Y	Erosion of natural deposits
---------	-----	---	---	------	----------	---	-----------------------------

Total Coliform	%	0	5	Highest Month = 0.6 Annual Average = 0.13	Y	Naturally present in the environment
----------------	---	---	---	--	---	--------------------------------------

Total Trihalomethanes	ppb	NA	80	42.6	27 to 51	Y	Byproduct of drinking
-----------------------	-----	----	----	------	----------	---	-----------------------

Haloacetic Acids(5)	ppb	NA	60	16.1	2 to 30	Y	Type I disinfection byproduct water chlorination

Chlorine	ppm	MRDLG = 4	MRDL = 4	Average = 0.94 Range = 0.5 to 1.4	Y	Water additive use to control microbes
----------	-----	-----------	----------	--------------------------------------	---	--

MCLG: Maximum Contaminant Level Goal. The level in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best treatment technology.

MRDL: Maximum Residual Disinfectant Level. The level of a contaminant in disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal. The level of water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TT: Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

NTU: Nephelometric Turbidity Unit. Turbidity is a measure of how clear the water looks. It was 0.3 NTU for at least 95% of the samples in a month. 100% of Tolt samples in 2024 were below 0.3 NTU

NA: Not Applicable
ND: Not Detected
ppm: 1 part per million = 1 mg/L
ppb: 1 part per billion
1 ppm = 1000 ppb

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not drinking water meets health standards.

Lead and Copper Results (samples collected at customer taps)
--

Parameter and Units	MCLG	Action ¹ Levels	Combined Regional Monitoring		WD119 - 2011	Source
			2016 Results ²	Homes Exceeding	Homes Exceeding	

Lead, ppb	0	1.5	3	2 of 50	0 of 3	Corrosion of household
-----------	---	-----	---	---------	--------	------------------------

Copper, ppm	1.3	1.3	0.10	0 of 50	0 of 3	plumbing systems
-------------	-----	-----	------	---------	--------	------------------

¹ The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

² 90th Percentile: i.e. 90 percent of the samples were less than the values shown.

LEAD AND COPPER

WD119 is confident with the quality of our water source. The water does not naturally contain lead or copper. Many people do not realize that the pipes in their home can have an impact on the quality of their drinking water. Of particular concern are homes that have copper pipe with lead solder (primarily homes plumbed with copper pipe prior to 1980) or homes that do not meet the plumbing code.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WD119 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at their website:

<http://www.epa.gov/safewater/lead>.

Here are a few simple things you can do to protect your water if you have plumbing with lead components.

1. If you haven't used your water for over 6 hours, run the tap for two minutes before drinking or cooking with it. (Don't forget to save! The water you run to flush your pipes can be used for watering plants or doing the dishes.)
2. Always use the COLD water tap for drinking and cooking—lead dissolves more quickly in hot water. Never make baby formula or other drinks or food for children from the HOT water tap.
3. Be sure to select low-lead or no-lead plumbing fixtures.

Since January 2014 manufacturers can have only 0.25% lead in a fixture, reduced from 8% previously.

ADDITIONAL REPORTING

UCMR4 MONITORING

Unregulated Contaminant Monitoring Rule 4 (UCMR4) data are reported to let you know about new contaminants that may be regulated in the future. The EPA requires water suppliers to monitor contaminants that do not have defined health-based standards. The EPA uses this information to determine the occurrence of contaminants in drinking water systems, which may lead to future regulations. The contaminants monitored were selected through a data-driven process that considered adverse health effects (potency and severity) and occurrence (prevalence and magnitude), but additional health information is needed to know whether the contaminants pose a health risk. For more information about the program, visit EPA's website at:

<https://www.epa.gov/dwucmr/fourth-unregulated-contaminant-monitoring-rule>

2024 MONITORING RESULTS

Analyte	Range (ppb)	Average (ppb)
Dichloroacetic Acid	1.0 to 14.1	6.9
Trichloroacetic Acid	0.9 to 14.0	8.7
Bromochloroacetic Acid	1.00 to 1.03	1
Dibromoacetic Acid	0.5	0.5

CROSS-CONNECTIONS, BACKFLOW, AND WATER QUALITY

Backflow from common household plumbing fixtures connected to drinking water pipes, a cross-connection, can impact your drinking water quality. For example, if a garden hose connected to your home plumbing system is left in the sun, the water can heat up and flow back to your house, affecting the taste and odor of your drinking water. Some backflows can become hazardous. For example, a sudden drop in water pressure from a water main break can cause water that may not be safe for consumption to flow into a building's drinking water pipes and potentially into the public water system from residential, commercial, or institutional properties that don't have required backflow prevention equipment. WD119's cross-connection control program helps protect the drinking water from potentially harmful backflow events. We partner with our water customers to keep the drinking water safe; this means working together to protect home drinking water from potentially hazardous connections. Learn more about cross connections and protecting your drinking water at:

seattle.gov/utilities/backflow.

WATER CONSERVATION

WD119 Efforts

WD119 has adopted a water conservation goal in accordance with Washington State's Water Use Efficiency Rule. The rule requires the system's conservation goal be re-established at a minimum of every six years, and that progress toward the goal be reported annually to the state and our customers. The performance report covers the conservation goals, distribution leakage and metering.

WD119 has had an active water conservation program since the 1990's. Water use efficiencies have been achieved through conservation programs, seasonal water rates, customer education and system leak detection. Our unaccounted for water was less than 20% of the total water purchased in 2024. Unaccounted for water consists of water lost due to main breaks, pipeline leakage, theft, fire protection and inaccurate meters. Here's what you can do to prevent or reduce leaks, which could save a lot of money on your water bill:

- Check your water meter for a spinning dial.
- Replace worn toilet flappers.
- Replace worn washers and gaskets in faucets, showerheads and hoses.
- Keep an eye out for unusually damp or green patches in your yard; these could be a sign of an underground leak.
- Check irrigation systems each spring for freeze damage and broken parts.
- Visit savingwater.org or call (206) 684-7283 for more water saving advice.

Regional Efforts

WD119 adopted the Saving Water Partnership (SWP) Regional Conservation Program Water Use Efficiency goal of keeping the total average annual retail water use of SWP members under 110 mgd through 2028, despite forecasted population growth, by reducing per capita water use. WD119 is one of 19 utilities that purchase wholesale water from SPU and is part of the Partnership administered by SPU. In 2024, the Partnership met the Regional Conservation Goal, with annual retail water use of members of SWP, using 94.5. The SWP has met previous goals consistently.

Get trusted information from SPU and from the Saving Water Partnership on how to use water wisely, including tools, tips and rebates at savingwater.org. Here are some great ways to save water and lower your water bills.

- Check for leaks and fix them as soon as you can; follow the step-by-step videos at savingwater.org or call 206-684-SAVE (7283) to learn more.
- Water saving rebates are available for low water use plumbing fixtures. Learn more at <http://www.seattle.gov/utilities/services/water/reduce-water-use/water-saving-rebates>
- Use less water in your garden by putting a thick layer of mulch around your plants. Learn more at: <http://www.seattle.gov/utilities/environment-and-conservation/lawn-and-garden/smart-watering>
- For water saving advice in your garden: call the Garden Hotline at (206) 633-0224 or use e-mail to contact help@gardenhotline.org.

WD119 WATER SYSTEM FACTS

- | | |
|--|---------|
| • Square miles served | 13.50 |
| • Number of connections | 1,310 |
| • Average water usage
(gallons per day per residence) | 196 |
| • Water Storage capacity (gallons) | 898,000 |
| O'Dell tanks | 420,000 |
| Lake Joy tanks | 300,000 |
| Cherry Garden tank | 178,000 |
| • Miles of water main | 36 |
| • Number of fire hydrants | 242 |
| • Number of pump stations | 4 |
| • Number of pressure reducing stations | 7 |

FOR MORE INFORMATION

- | | |
|-------------------------------------|--|
| WD119 Email | office@wd119.org |
| WD119 Telephone | (425) 788-2885 |
| WD119 Fax | (425) 788-6787 |
| WD119 Office Address | 32730 NE Big Rock Road
Duvall, WA 98019 |
| WD119 Mailing Address | 32730 NE Big Rock Road
Duvall, WA 98019 |
| WSDOH web | www.doh.wa.gov/ehp/dw/ |
| EPA web site | www.epa.gov/safewater |
| EPA Drinking Water Hotline | 1-800-426-4791 |
| EPA Drinking Water Hotline
Email | sdwa@epamail.epa.gov |

This material can be made available to accommodate people with disabilities and those who need language translation if the need arises by contacting the WD119 office at the above noted telephone number.

WATER CONSERVATION GUIDANCE



We share our water with the entire ecosystem. Each gallon you save helps keep water in our rivers and lakes to sustain salmon, trout, other wildlife, and in our forests.

When you conserve water, you help our ecosystems thrive for generations to come. Conserving water in the summer and fall helps adult salmon who are returning to rivers to spawn when stream flows are naturally low.



There are everyday actions we can all take to use water wisely:

- Fix leaks right away. Fixing leaks prevents water waste and saves money.
- Upgrade older water-using appliances in your home to newer, more efficient models. Go to [savingwater.org](https://www.savingwater.org) to learn more about rebates to replace old toilets.
- Choose plants for your yard or garden that are well suited to the Pacific Northwest climate and need less water.
- Build better soil with compost and mulch. Healthy soil absorbs water easily, drains well, and retains moisture. You know it's time to invest in soil health when your higher-water use plants (like lawns or annuals) need more than an inch of water per week, including rain, in the summer.
- Visit [savingwater.org](https://www.savingwater.org) for gardening tips, videos, and classes.



Sprinkler system and Underground Leaks:

Fix leaks right away to prevent water waste and save money. Outdoors, watch for unusually damp or green patches in your yard, which could be a sign of an underground leak. Watch a step-by-step video on how to use your water meter to check for leaks at www.savingwater.org/how-to-videos

It's also a good idea to check your sprinkler system for leaking valves and broken parts each month it's turned on.



Toilets are the top source of leaks and can waste as much water as taking 15 showers a day (or more). If you have a high water bill, toilets are the first place you should check. Find and fix toilet leaks.

For many homeowners, fixing a running toilet is a do-it-yourself project that usually costs less than \$20. If you are a renter, report the leak to your landlord right away.

WATER QUALITY AND YOU

<i>Sources of Drinking Water</i>	<i>Are Contaminants a Health Risk?</i>
Common sources of drinking water, both tap and bottled water, include rivers, lakes and streams (surface water) and wells and springs (groundwater). As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material. The water can also pick up substances resulting from the presence of animals or from human activity. Substances that may be present in our source water include: • Microbial Contaminants, such as viruses and bacteria, which may come from wildlife; • Inorganic Contaminants, such as salts and metals, which are naturally occurring; • Organic Chemical Compounds, which result from chlorine combining with the naturally occurring organic matter; • Radioactive Contaminants, which can be naturally occurring. Our water travels from the Cascade Mountain watersheds and is then treated at the Tolt Reservoir to ensure it is free of contaminants before being sent through water mains to the pipes in your home.	To ensure that tap water is safe to drink, the Environmental Protection Agency and the Washington State Department of Health prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration and the Washington State Department of Agriculture have similar regulations which establish limits for contaminants in bottled water, providing the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, the elderly and some infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).
<i>PFAS</i>	<i>System Updates</i>
PFAS are human made chemicals. PFAS (per- and polyuroalkyl substances) are a category of manufactured chemicals used in everyday products like waterproof jackets, food packaging, and nonstick pans, since the 1940s. PFAS are also found in firefighting foams, and their use at airports and military bases has been linked to the contamination of aquifers. PFOS and PFOA are types of PFAS. Because PFAS don't break down in the environment, they are sometimes called "forever chemicals." Scientific studies have shown that exposure to some PFAS in the environment may be linked to harmful health effects in humans and animals. Routine testing has only recently been required. To protect human health SPU monitors its drinking water supply to detect PFAS. Test results have shown no detections of PFAs in the Tolt and Cedar watersheds relative to recently established state and federal regulations. Those results and additional information can be found at: seattle.gov/utilities/PFAS	There are parts of the District's distribution system which are nearly 60 years old. The District will be replacing as part of our Capital Improvement Plan the older water mains and other mains which have experienced breaks. Sections of piping will be replaced on an annual basis depending on the construction bidding climate and as other District needs develop. Approximately 2,000 feet of pipe was replaced in 2022.